



October 5, 1994

OCT 06 1994

Mr. Dean Haymore
Storey County Building Official &
Planning Administrator
Storey County Building Dept.
P. O. Box 526
Virginia City, NV 89410

**ELEVATION CERTIFICATION
PROPOSED FINISH FLOOR ELEVATION
BY REGISTERED CIVIL ENGINEER**

Based on a field survey of Lot 193, Rainbow Bend Subdivision, located at 193 Avenue de la D'Emerald the highest existing pad grade has been determined to be 4352.4. This lot is located within Flood Zone AO (depth 1 foot). Therefore, the minimum finish floor elevation shall be 4353.4. Final finish floor verification will be required prior to issuance of a Certificate of Occupancy.


Clinton G. Thiesse, P.E.
Vice President



lcraig@elevcert.193

5405 Mae Anne Avenue • Reno, Nevada 89523 • (702) 747-8550 FAX (702) 747-8559
3684 S. Highland Drive • Las Vegas, Nevada 89103 • (702) 252-3236 FAX (702) 252-3247
607 South Fifth Street • Elko, Nevada 89801 • (702) 738-8058 FAX (702) 738-8267